

MEMORANDUM

FILE: **District Policy Manual 20.2.2**
TO: District Engineers, Interested Parties
THROUGH: Lou Harmon, Water and Wastewater Section Manager
FROM: Brian Mark, Principal Engineer
DATE: September 23, 2009



SUBJECT: WQD Chapter 5, Operator Certification: Definition of Booster Station For Purposes of System Classification.

Background: This policy is meant to clarify the definition of a booster station in Water Quality Rules and Regulations, Chapter 5, Section 6(c).

Policy 20.2.2

- 1) District Engineers shall determine the status of booster stations. The pump must deliver 75 gpm or more at the pump duty point to be considered a booster station. In addition, the pump shall serve 15 or more service connections.
- 2) A booster station is a facility that moves water from one pressure zone to a higher pressure zone.
- 3) All pertinent sections of Chapter 12, Section 12 remain in effect.